

Multipoint Lockouts

Only Qualified Persons can complete a Multipoint Lockout, and they must use **red operating locks and follow the multipoint procedure**



After confirming the scope of work, one Qualified Person must print the name of the lockout as follows:


White
11x17" paper
folded
lengthwise



Qualified Persons need to count the locks on the lock rings being used and ensure they will have enough locks to do the lockout. The number of locks must match the number of locks indicated on the lock series tag ring.

All locks on each ring must be the same series number.

The full Multipoint lockout must be completed by the same two people from start to finish. If there is a shift change in the middle of the lockout and the two workers starting the lockout cannot complete it, new paperwork and lockout tags must be created and the full lockout must be walked down.



Multipoint lockout checklists must be kept for a minimum of 30 days after de-lock (lockout tags can be discarded).

